



NORTH COUNTY FIRE PROTECTION DISTRICT

BIDDER QUESTIONS AND ANSWERS – FROM MANDATORY MEETING ON SEPTEMBER 14, 2020

QUESTIONS AND ANSWERS

Q:	Will the automatic sliding gate need an Opticom to open the gate?
A:	Yes
Q:	Will the automatic sliding gate need a Knox box to access the gate?
A:	No
Q:	Will electrical power be pulled to the automatic gate for the motor and keypad?
A:	Yes, we will have an electrician coordinate with the selected contractor and install electrical power to the area of the keypad and gate motor
Q:	Is panic hardware needed for the swing gate?
A:	No
Q:	Does the curb need to be saw cut for the automatic gate installation?
A:	Yes
Q:	Does the fence go around the Canary Island palm tree on the northeast side of the property
A:	No, we decided to install the fence line south or before the palm and therefore the 45 degree fence angle has been eliminated
Q:	Are chain link fabric or privacy slats to be utilized?
A:	Privacy slats
Q:	What percentage of coverage for the privacy slats are to be used?
A:	85 percent
Q:	What color of privacy slats are to be used?
A:	To be determined
Q:	Do permits need to be pulled?
A:	No
Q:	Define the term heavy gauge chain link mesh
A:	A minimum of 11-gauge chain link mesh is required